

ADDENDUM REPORT PLANNING COMMITTEE 26th APRIL 2007

Item: 12
Site: Estover Primary School, Miller Way, Estover, Plymouth, PL6 8UJ
Ref: 07/00486/FUL
Applicant: Plymouth City Council
Page: 115

Members attention is drawn to the addendum report for the above application.

Since making the recommendation on this application, a consultation response has been received from the City Council's Access Consultant. The consultation response recommends that handrails on paths should be provided to both sides of the paths, unless the gradient is less than 1 in 20.

It is recommended that this observation is communicated to the applicant/agent, by way of an additional informative note on the grant of planning permission.